

Assistant Engineer Grade - I,
Public Works Sub - Division ,Hatkanangale

Telphon No :- 0230 - 2483398	Fax No. :- 0230 - 2483398
E - mail ID :- hatkanangalepwd@gmail.com	Website :- www.mahapwd.com

No./Hat/PB/ १२९६ /2021

Date. १८/०८/२०२१

To,

✓ Office Superintendent,
Balasaheb Mane Education Trust,
Rukadi, Tal- Hatkanangale Dist.- Kolhapur

Subject : - Issue Of Building Safaty Certificate

Refernce: - Our Office Letter dated 13/08/2021

With Refference to our above Letter dated 13/08/2021 I Visited our School Building today (date 18/08/2021) and inspected visuallly as per this visual inspection this office reported that,

- 1) This Building is R.C.C. Framed Structure type G + 2 storied building whose ground floor is constructed in 1991.
- 2) Age of building is near about 30 years.
- 3) Acording to visual inspection of this building - this building is generally Safe and Stable for use today.

For detail Stability Report it requires detailed Structural Audit from audit Agency
This is for your information and necessary action.


Assistant Engineer Grade-I,
P.W.Sub- Din.Hatkanangle

Copy - Hon.Executive Engineer, .P.W.Division, Kolhapur for information.

Copy -Shri.S.S.Patil,Sect.Eng. P.W.Sub - Division, Hatkanangale for further followup.

जा. क्र./आ.प./वशी/.11.6./20.21

ग्रामपंचायत रुकडी, ता. हातकणंगले

दि. 12/08/2021



ग्रामपंचायत रुकडी



ता. हातकणंगले जि. कोल्हापूर

E-mail - gprukdi@gmail.com

जन्म-मृत्यू व विवाह नोंद २१ दिवसात ग्रामपंचायतकडे करा

घरफाळा व पाणीपट्टी वेळेत भरून सहकार्य करा

पाणी जपून वापरा पाणी उकळून गाळून पिणे योग्य

.बालविवाह टाळा

.कुटुंब नियोजन करा लेक वाचवा देश वाचवा

.आपले आरोग्य आपल्या हाती

phone no-0230-20585527

.घरोघरी वैयक्तिक शौचालय बांधा

.आपला गाव स्वच्छ सुंदर व रोगराई मुक्त

.एड्स म्हणजे मृत्यू

CERTIFICATE

THIS IS TO CERTIFY THAT THE BULDINAG STRUCTURE DEVELOPED BY BALASAHEB MANE EDUCATION TRUST IN RUKADI IN GRAMPANCHAYT MILAKAT NO.5393 FOR EDUCATIONAL PURPOSE IS WELL FOR USE IN GOOD CONDITAION FULLY SAFE FOR USE

THIS CERTIFICATE ISSUED BY US IN REQUEST LETTER OF SUPRITENDEDT OF THE BALASAHEB MANE EDUCATION TRUST FOR OFFICAL PURPOSE

Reference: - Our Office Letter dated 13/08/2021

W/O. P. S. Patil is our above letter dated 13/08/2021

सं. सरपंच
ग्रामपंचायत रुकडी
ता. हातकणंगले, जि. कोल्हापूर

1) The Building is R.C.C. Framed Structure type G + 2 stored building whose ground floor is constructed in 1991

2) Age of building is near about 30 years

3) According to visual inspection of this building - this building is generally safe and stable for use today.

For detail Status- Report it requires detailed structural Audit from audit Agency.

This is for your information and necessary action.

Assistant Engineer Graded
P.W. Sub-Div. Hatkanangale

Copy - Non-Executive Engineer, P.W. Division, Kolhapur for information.

Copy - Shri. S. S. Patil, Sect. Eng. P.W. Sub-Division, Hatkanangale for further followup.